

**J. R. HENDERSON LABS, INC**  
 123 SEAMAN AVENUE  
 BEACHWOOD, NEW JERSEY 08722-2817

Neeta School  
 44 Neeta Trail  
 Medford Lakes, NJ

Sample Date: 11-10-16

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME/CODE	RESULTS MG/L	ANALYTICAL METHOD	ANALYSIS DATE/TIME
NE-1	PS-1 Sink Middle School near Rm. 312	11-10-16/07:01	LEAD/1030	0.016	200.9	11-17-16/11:33
NE-2	WF-11 Water Fountain Main Hall near Rm. 209	11-10-16/07:02	LEAD/1030	<0.001	200.9	11-17-16/11:37
NE-3	WF-12 Water Fountain Middle School near Gang Baths near Rm. 300	11-10-16/07:03	LEAD/1030	<0.001	200.9	11-17-16/11:42
NE-4	WF-13 Water Fountain Middle School near Rm. 310	11-10-16/07:07	LEAD/1030	<0.001	200.9	11-17-16/11:46
NE-5	WF-14 Water Fountain Middle School near Rm. 308	11-10-16/07:09	LEAD/1030	<0.001	200.9	11-17-16/11:50
NE-6	WF-1 Water Fountain Main Hall near Library	11-10-16/07:11	LEAD/1030	<0.001	200.9	11-17-16/11:54
NE-7	WF-2 Water Fountain Main Hall near Library	11-10-16/07:12	LEAD/1030	<0.001	200.9	11-17-16/11:59
NE-8	S-1 Sink Nurses Office	11-10-16/07:14	LEAD/1030	<0.001	200.9	11-17-16/12:03
NE-9	WF-4 Water Fountain Elementary Wing near Rm. 120	11-10-16/07:16	LEAD/1030	<0.001	200.9	11-17-16/12:07
NE-10	WF-3 Water Fountain Elementary Wing near Rm. 120	11-10-16/07:18	LEAD/1030	<0.001	200.9	11-17-16/12:29
NE-11	S-5 Sink Elementary Wing in Rm. 120	11-10-16/07:20	LEAD/1030	<0.001	200.9	11-17-16/12:57
NE-12	WF-5 Water Fountain Elementary Wing near Gang Bathrooms	11-10-16/07:21	LEAD/1030	<0.001	200.9	11-17-16/13:01
NE-13	WF-6 Water Fountain Elementary Wing near Gang Bathrooms	11-10-16/07:22	LEAD/1030	<0.001	200.9	11-17-16/13:05
NE-14	WF-7 Water Fountain Elementary Wing near Rm. 107	11-10-16/07:23	LEAD/1030	<0.001	200.9	11-17-16/13:09
NE-15	WF-8 Water Fountain Elementary Wing near Rm. 107	11-10-16/07:24	LEAD/1030	<0.001	200.9	11-17-16/13:14
NE-16	S-6 Sink Elementary Wing Teachers' Lounge Rm. 107	11-10-16/07:26	LEAD/1030	0.002	200.9	11-17-16/13:31
NE-19	MS-1 Sink Maintenance Office Rm. 404	11-10-16/07:37	LEAD/1030	<0.001	200.9	11-17-16/13:35
NE-20	KS-1 Sink Kitchen Rm. 403	11-10-16/07:39	LEAD/1030	<0.001	200.9	11-17-16/13:40
NE-21	KS-2 Sink Kitchen Rm. 403	11-10-16/07:41	LEAD/1030	0.001	200.9	11-17-16/13:44
NE-22	KS-3 Sink Kitchen Rm. 403	11-10-16/07:42	LEAD/1030	0.002	200.9	11-17-16/13:48
NE-23	WF-16 Water Fountain APR Entrance Lobby	11-10-16/07:44	LEAD/1030	<0.001	200.9	11-17-16/14:20
NE-24	WF-15 Water Fountain APR Entrance Lobby	11-10-16/07:45	LEAD/1030	0.006	200.9	11-17-16/14:38

MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).

Notes:

**J. R. HENDERSON LABS, INC**  
 123 SEAMAN AVENUE  
 BEACHWOOD, NEW JERSEY 08722-2817

Nokomis School  
 135 Mudjekeewis Trail  
 Medford Lakes, NJ

Sample Date: 11-10-16

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME/CODE	RESULTS MG/L	ANALYTICAL METHOD	ANALYSIS DATE/TIME
NE-1	S-1 Sink Nurses Office Rm. 504	11-10-16/07:08	LEAD/1030	<0.001	200.9	11-17-16/14:12
NE-2	S-2 Sink Nurses Office Rm. 504	11-10-16/07:12	LEAD/1030	<0.001	200.9	11-17-16/14:46
NE-3	WF-1 Water Fountain Start of APR Hall	11-10-16/07:04	LEAD/1030	0.001	200.9	11-17-16/14:51
NE-4	SF-6 Sink Fountain Rm. 520	11-10-16/07:10	LEAD/1030	0.008	200.9	11-17-16/14:55
NE-5	SF-1 Sink Fountain Rm. 525	11-10-16/07:13	LEAD/1030	0.006	200.9	11-17-16/14:59
NE-6	SF-5 Sink Fountain Rm. 521	11-10-16/07:14	LEAD/1030	<0.001	200.9	11-17-16/15:03
NE-7	WF-2 Water Fountain APR Upper Hall	11-10-16/07:14	LEAD/1030	<0.001	200.9	11-17-16/15:08
NE-8	SF-2 Sink Fountain Rm. 524	11-10-16/07:16	LEAD/1030	<0.001	200.9	11-17-16/15:12
NE-9	SF-4 Sink Fountain Rm. 527	11-10-16/07:18	LEAD/1030	0.007	200.9	11-17-16/15:57
NE-10	SF-3 Sink Fountain Rm. 523	11-10-16/07:18	LEAD/1030	<0.001	200.9	11-17-16/16:01
NE-11	SF-7 Sink Fountain Rm. 518	11-10-16/07:17	LEAD/1030	0.004	200.9	11-17-16/16:05
NE-12	SF-8 Sink Fountain Rm. 517	11-10-16/07:19	LEAD/1030	0.010	200.9	11-17-16/16:13
NE-13	SF-9 Sink Fountain Rm. 516	11-10-16/07:20	LEAD/1030	<0.001	200.9	11-17-16/16:18
NE-14	WF-3 Water Fountain Teachers' Lounge Hall	11-10-16/07:22	LEAD/1030	<0.001	200.9	11-17-16/16:22
NE-15	S-3 Sink Teachers' Lounge Rm. 506	11-10-16/07:24	LEAD/1030	<0.001	200.9	11-17-16/16:26
NE-16	SF-10 Sink Fountain Rm. 510	11-10-16/07:22	LEAD/1030	0.027	200.9	11-17-16/16:47
NE-17	WF-4 Water Fountain Rm. 507	11-10-16/07:24	LEAD/1030	<0.001	200.9	11-17-16/16:51
NE-19	WF-6 Water Fountain Rm. 508	11-10-16/07:26	LEAD/1030	<0.001	200.9	11-17-16/16:55
NE-20	WF-7 Water Fountain Teachers' Lounge Hall by Rm. 506	11-10-16/07:41	LEAD/1030	<0.001	200.9	11-17-16/17:27
NE-21	WF-8 Water Fountain Main Hall by Rm. 516	11-10-16/07:19	LEAD/1030	<0.001	200.9	11-17-16/17:32
NE-22	WF-9 Water Fountain Main Hall by Rm. 518	11-10-16/07:20	LEAD/1030	<0.001	200.9	11-17-16/17:36

MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).

Notes:

11-18-16